

mail: eerwss_kld@gmail.com

Phone No: 06670-230784

**OFFICE OF THE SUPERINTENDING ENGINEER,
KALAHANDI RWS&S DIVISION, BHAWANIPATNA**

Letter No.

3045

/Dated/

03.07.2025

To

Principal,
Ekalavya Model Residential School,
Saisurni, Gunpur,
Kalahandi.

Sub ; Water testing report and sanitary condition Certificate.

Ref ; Your Letter No- emrs/Th. Rampur/2025-26 /83 / Dated – 30.06.2025.

Sir,

With reference to above , the safe drinking water and sanitary condition
Certificate of enclosed herewith for your information & necessary action.

Encl: As above.

Yours Faithfully,

Superintending Engineer,
Kalahandi RWS&S Division,
Bhawanipatna.

S. S. S. S. S.

03.07.2025

WATER SAMPLE TESTING REPORT

District Water Testing Laboratory, Kalahandi RWS&S Division, Bhawanipatna

Sl. No.	Name of The Block/NAC	Name of the Village	Name of the Habitation	Source	Temperature	pH	Calcium (mg/L)	Magnesium (mg/L)	Colour (H2U)	Odour	Taste	Chloride (mg/L)	Total Iron (mg/L)	Fluoride (mg/L)	Hardness mg/L (as CaCO3)	Alkalinity mg/L (as CaCO3)	Turbidity (NTU)	TDS (mg/L)	Conductivity	Total coliform	
1	Th. Rampur	Gunpur	Saisurni	EMRS, Saisurni	T/W	25.4	7.52	36.2	42.6	3.0	Agreeable	Agreeable	96	0.524	0.96	298	256	1.52	626.4	963.8	Absent
Remarks: Water Samples Collected by EMRS, Saisurni School Staff.																					
Permissible limits:						6.5 to 8.5 pH	75 to 200 (mg/L)	30 to 100 (mg/L)	5 to 15 (Hazen unit)	Agreeable	Agreeable	250 to 1000 (mg/L)	1.00 (mg/L)	1.0 to 1.50 (mg/L)	200 to 600 mg/L (as CaCO3)	200 to 600 mg/L (as CaCO3)	1.0 to 5.00 (NTU)	500 to 2000 (mg/L)		Absent	

S.S. Jena
03.07.2025
Lab Chemist
District Water Testing Laboratory,
Kalahandi RWS&S Division,
Bhawanipatna.


Superintendent Engineer,
Kalahandi RWS&S Division,
Bhawanipatna.

APPENDIX - VIII

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 3046

Date: 03.07.2025

It is certified that an inspection team headed by A.E. RWS&S Section, Th. Rampur
(Name of Officers with designation) from Kalahandi R. W. S & S Division, Bhawanipatna. (Name of
Department/Office) inspected the Ekalavya Model Residential School, Saisurni,
(Name & Address of the School) on 02.07.2025 and found that the
Ekalavya Model Residential School. (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per the norms prescribed by the
Central/State/U.T Govt.

The above valid for a period of: One Year.

Signature with Seal :


**Superintending Engineer
Kalahandi RWS & S Division
Bhawanipatna**

Name

: Rajesh Kumar Gararayak.

Designation

: Superintending Engineer.

To

Principal, Ekalavya Model
Residential School, Saisurni,
Gunpur, Th. Rampur, Kalahandi,

(Name & Address of the Institution)